

## Public Works

### Council Report

May 21 2019

- Lagoon Spring discharge has begun. Samples from the lagoon have been sent away to be tested, and the discharging of cell 2 is going smoothly. It should be finished draining in the next two weeks.
- Street sweeping is an ongoing project that is happening on a weekly basis.
- Plans are still in the works to replace water main valve on Main St. The frost is still surrounding the pipes so we still have to hold off from digging. If we were to dig with frost surrounding the pipes, that would create a lot of down pressure from the backhoe resulting in bursting the water lines. Digging and replacing valves can only happen once the frost has melted. There are at least 5 valves to replace on main st.
- Public works crew cleaned out the retention chamber at the water plant. There was lots of build-up of iron in the chamber causing the filters to filter out more iron than normal. When cleaning out the chamber, public works crew found a leak in one of the pipes resulting raw well water seeping into the clean filtered water. The pipe has been fixed and now the test numbers have dropped and cleaner water is being distributed.
- Town wide clean-up has started this week; public works crew will be busy moving people's unused items to the garbage bins throughout the week as well as sorting the items that are being dropped off at the bins placed at the shop.
- Public works crew will be starting to go through the running water orders next week starting May 27 to shut off the drip lines.

Jordan Theisen